




DeKalb County Department of Planning & Sustainability

Lee May
Interim Chief Executive Officer

Andrew A. Baker, AICP
Director



Erosion and Sediment Control (ES&C) Plan Review Checklist for Building Permit Plan Additions

- **Show graphic scale and north arrow.**
- **Delineate all wetlands and state waters located on or within 200 feet of the project site.**
- **Delineate 25-foot undisturbed state buffers of state waters and 50-foot buffers along designated streams from wretched point of vegetation.**
- **Delineate 75-foot undisturbed county buffers of state waters from wretched point of vegetation.**
- **Variance from DeKalb County required for encroachment in 25-foot state waters buffers.**
- **Show double row Type-C slit fence between land disturbing activity and state waters, wetlands, and/or I.R.F.**
- **Show limits of disturbance on E&SC plans.**
- **Provide name, address and phone number of developer/owner.**
- **Provide name and phone number of 24-hour local erosion and sediment control contact.**